



Energy Calculations + Ventilation (Be10)

JAN REYNDERS

MARCANDRÉ KUHNERT

MICAEL PEPE

Table of content:

1. General
 - 1.1 Dividing of building
 - 1.2 General energy concept of building
2. Month average calculation (estimate)
 - 2.1 Month average calculation of commercial area
 - 2.2 Month average calculation of accommodation
3. Drainage, water and utility shafts
 - 3.1 Shaft diagram
 - 3.2 Apartment plan
4. Mechanical ventilation
 - 4.1 General
 - 4.2 Ventilation calculation (+duct sizing)
 - 4.3 Ventilation section
 - 4.4 Ventilation plan
5. Natural ventilation
 - 5.1 General
 - 5.2 Natural ventilation winter time
 - 5.3 Natural ventilation summer time
6. BE10
 - 6.1 Commercial area
 - 6.2 Student accommodation

1. General

1.1 Dividing of building

„Punto de Reunion“ is a multi storey building of 3 storey's high and a ventilated basement. The building is divided in different functions for each floor.

- Basement for parking and utilities (ventilation system, heating, water,...),
- Groundfloor for commercial activities:
 - Bar/lounge
 - Spa/wellness
 - Office space for spa
 - First aid/ doctors practice
 - Polyvalent space
- First floor for student accommodation
- 2nd floor for penthouse

Due to this mixed use of the building we separated the building according to functionality. The Groundfloor (1321 m²) was taken as commercial area, the 1st and 2nd floor (1182 m²) are seen as accommodation or dwellings. The basement is left out of the calculation since this space is naturally ventilated and does not require additional heating or cooling.

If the commercial area occupied less than 20% of the total floor area of the building, this could be included in the calculation for the accommodation. But since the commercial area consists of

$$1321 / (1321+1182) = 0.52 \rightarrow 52\%$$

of the total floor area we had to separate the building into different areas to do the calculations accurately (see chapter 2 and 6).

1.2 General energy concept of the building

Our client's roots are located in Mexico, so in this building we wanted to recreate an indoor climate that could resemble that of Mexico.

The way we did this is by splitting the building into 2 pieces and opening up the space in between towards the south. This way we achieved a maximum amount of solar gain. To optimise the use of this solar load and enable the growth of more exotic plants on the property we decided to connect the two building masses by a winter garden, acting as a giant greenhouse.

Further more we wanted to store as much as possible of this solar load, so we worked, especially on the groundfloor, with heavy materials like concrete and rammed earth wall. These materials have a high thermal mass, so they are excellent in storing heat. The higher the building, the lighter the material, thus optimising the heat stack upwards.




Figure 1: Solar path on building (21 June)

All together we would have a energy consumption of 83.2 kWh/m²/year which is far above the average energy consumption found in low energy buildings (class 2: 51.2 and class 1: 35.8).


Some of the measurements we took to reduce the heat consumption in the commercial area are:

Passive measurements :

- Wintergarden
- Combination of big windows and Thermal mass to store the solar heat (1:6 ratio)
- Heat corridor's for natural ventilation (also for overheating in summer)

Active measurements:

- Controlable shading (also for overheating in summer)
- *Heat pum



Graph 1: Month average calculation commercial area: Energy consumption throughout the year

Tabel 2: Characteristics of the building; commercial area

Characteristics of the building**Constructions towards outdoor**

A m ²	Description	U W/m ² K	Bu W/K
133,95	nordvæg	0,15	20,0925
138,231	østvæg	0,15	20,73465
119,9	vestvæg	0,15	17,985
0	sydvæg	0,15	0
1361,4	tag	0,1	136,14
			0
			0
			0
			0

Specific heat loss, constructions towards outdoor, (W/K) 194,95215 = Bu,con

Windows

A m ²	Direction	U W/m ² K	Bu W/K	g-value [-]	f(beta) [-]	f(shade) [-]	f(shadow) [-]	f(glass) [-]	Fsun [-]
43,97	N	0,79	34,7363	0,51	0,9	0,65	0,5	0,9	0,1342575
124,066	NE	0,79	98,01214	0,51	0,9	0,65	0,8	0,9	0,214812
78,15	E	0,79	61,7385	0,51	0,9	0,65	0,5	0,9	0,1342575
	SE		0						0
178,323	S	0,79	140,87517	0,51	0,9	0,65	0,9	0,9	0,2416635
	SW		0						0
	W		0						0
163,31	NW	0,79	129,0149	0,51	0,9	0,65	0,5	0,9	0,1342575
	Skylight		0						0

Specific heat loss, windows, (W/K) 464,37701 = Bu,win

Specific heat loss, outdoors, total, (W/K) 659,32916 = Bt (=Bu,con+Bu,win)

Floor

A m ²	U W/m ² K	Bu W/K
1253	0,15	187,95
		0
		0
		0
		0

Specific heat loss, floor, (W/K) 187,95 = Bu,floor

Heat capacity

Heat capacity, Wh/Km ²	160
Time constant	77,4
a	5,8

Tabel 3: Ventilation commercial area

Ventilation**Ventilation rate, summer**

Service hours, l/s m ²	2,78
Outside service hours, l/s m ²	0,69
Average ventilation rate, m ³ /s	2,02

Ventilation loss, summer, W/K 2437 = Bv,summer

Ventilation rate, winter

Service hours, l/s m ²	0,69
Outside service hours, l/s m ²	0,69
Average ventilation rate, m ³ /s	0,87

Ventilation loss, winter W/K 1050 = Bv,winter

Internal heat loads


Hour	Person load W	Ligthing W	Other W	Total W
1	0	0	500	500
2	0	0	500	500
3	0	0	500	500
4	0	0	500	500
5	0	0	500	500
6	0	0	500	500
7	265	4084	800	5149
8	663	4084	800	5547
9	663	4084	800	5547
10	663	4084	800	5547
11	663	4084	800	5547
12	1658	4084	800	6542
13	2231	4084	800	7115
14	2231	4084	800	7115
15	1658	4084	800	6542
16	1658	4084	800	6542
17	1989	4084	800	6873
18	2652	4084	800	7536
19	3978	4084	800	8862
20	3978	4084	800	8862
21	3978	4084	800	8862
22	3978	4084	800	8862
23	1685	4084	800	6569
24	265	4084	500	4849
Total	32867	73512	17100	123479
Average	1369	3063	713	5145

Help for internal loads

Heat from persons:		Activity level met	Total W/person	Sensible heat W/person	Number of persons	Sensible, total W
		1.0	99	66	60	3978
Ligthing:		Level:	Incandescent lig	fluorescent	Lowenergy	Choose power
General		lux	W/m ² g.a.	W/m ² g.a.	W/m ² g.a.	W/m ² g.a.
		180	47	14	7	3
						4084


Tabel 4: Internal heat loads commercial area

2.1 Month average calculation of accommodation



Tabel 5: Month average calculation accommodation (heating and cooling)

In the *Month average calculation* for the accommodation area of the building find the same trend as in the commercial area. A high energy consumption for heating of 48.6 kWh/m²/year in comparisant to 0.0 kWh/m²/year for cooling. But unlike the commercial area it is not in this amount that it causes a problem in overall energy consumption of the building, since the accommodation still performs better then a energy class 2 house (48.6 kWh/m²/year vs 51.3 kWh/m²/year).



Graph 2: Month average calculation: Energy consumption throughout the year

This difference can be brought back to a lower service life, less glazing and a use of lighter construction materials. In this calculation the use of less glass and lighter construction materials will be beneficial for the outcome of the calculation, although this in practice might not be the case.

As we mentioned before, the combination of bigger windows and thermal mass (concrete floor/walls, rammed earth walls, soill in wintergarden) will contribute to a better preservation of the solar load instead of a loss to the outside. Another point is the orientation of the windows and thermal mass towards the wintergarden, which will lead to an even greater usage of solar power for the heat gain.

Characteristics of the building

Constructions towards outdoor

A m²	Description	U W/m²K	Bu W/K
154,702	nordvæg	0,15	23,2053
140,84	østvæg	0,15	21,126
135,802	vestvæg	0,15	20,3703
59,867	sødvæg	0,15	8,98005
1068,251	tag	0,1	106,8251
			0
			0
			0
			0
Specific heat loss, constructions towards outdoor, (W/K)			180,50675 = Bu.con

Windows

A m²	Direction	U W/m²K	Bu W/K	g-value [-]	f(beta) [-]	f(shade) [-]	f(shadow) [-]	f(glass) [-]	Fsun [-]
31,89	N	0,79	25,1931	0,51	0,9	0,65	0,5	0,9	0,1342575
53,112	NE	0,79	41,95848	0,51	0,9	0,65	0,8	0,9	0,214812
0	E	0	0	0	0	0	0	0	0
7,024	SE	0,79	5,54896	0,51	0,9	0,65	0,8	0,9	0,214812
60,955	S	0,79	48,15445	0,51	0,9	0,65	0,9	0,9	0,2416635
34,615	SW	0,79	27,34585	0,51	0,9	0,65	0,8	0,9	0,214812
0	W	0	0	0	0	0	0	0	0
4,848	NW	0,79	3,82992	0,51	0,9	0,65	0,5	0,9	0,1342575
29,25	Skylight	0,79	23,1075	0,51	0,9	0,65	0,8	0,9	0,214812
Specific heat loss, windows, (W/K)			175,13826 = Bu.win						
Specific heat loss, outdoors, total, (W/K)			355,64501 = Bt (=Bu.con+Bu.win)						
A m²	U W/m²K	Bu W/K							
1150,536	0,15	173,7804							
		0							
		0							
		0							
		0							
Specific heat loss, floor, (W/K)		173,7804 = Bu.floor							
Heat capacity, Wh/Km²	100								
Time constant	87,8								
a	6,5								

Tabel 6: Characteristics of the building: accomodation

Ventilation**Ventilation rate, summer**

Service hours, l/s m ²	1,67
Outside service hours, l/s m ²	0,42
Average ventilation rate, m ³ /s	0,83

Ventilation rate, winter

Service hours, l/s m ²	0,42
Outside service hours, l/s m ²	0,42
Average ventilation rate, m ³ /s	0,48

Ventilation loss, summer, W/K **998** =Bv,summer

Ventilation loss, winter W/K **582** =Bv,winter

Tabel 7: Ventilation accommodation

Internal heat loads

Hour	Person load W	Ligthing W	Other W	Total W
1	1016	0	0	1016
2	1016	0	0	1016
3	1016	0	0	1016
4	1016	0	0	1016
5	1016	0	0	1016
6	1016	0	0	1016
7	1016	0	0	1016
8	1548	3816	2000	7364
9	1548	3816	2000	7364
10	1548	3816	2000	7364
11	0	0	0	0
12	0	0	0	0
13	0	0	0	0
14	1548	0	1200	2748
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
18	1548	3816	2000	7364
19	1548	3816	2000	7364
20	1548	3816	2000	7364
21	1548	3816	2000	7364
22	1548	3816	2000	7364
23	1016	0	0	1016
24	1016	0	0	1016
Total	23076	30528	17200	70804
Average	962	1272	717	2950 =Phi

Pr. m ² floor area	Person load W/m ²	Ligthing W/m ²	Other W/m ²	Total W/m ²
Average	0,83	1,10	0,62	2,55

Help for internal loads					
Heat from persons:		Activity level met	Total W/person	Sensible heat W/person	Number of person
		1,4	138	86	18
					1548
Ligthing:		Level:	Incandescent lig W/m ² g.a.	fluorescent W/m ² g.a.	Lowenergy W/m ² g.a.
General		lux	120	31	10
					Choose power W/m ² g.a.
					5
					3
					3816

Tabel 8: Internal heat loads accommodation

3. Drainage, water and utility shafts

3.1 Shaft diagram

The *shaft diagram* gives a good overview of the different utilities that enter the building and more specific the different appartments.


It also shows the way the different pipes for the different utiluties must be organised.

The pipes that supply hot water must be insulated to prevent heat loss by transmission. The drainage pipe must be insulated as well, but his time to prevent unnecessary sound polution.

3.2 Appartment plan (utility plan)

The *apartment plan* shows the way the different utilities like drainage, supply of hot and cold water, circulated hot water, heating pipes (flow and return) and electricity are distributed throughout the floor plan.

It helps to place the different area's that need to be supplied (like kitchen, bathroom, toilet, ...) close together. This way you save on meters of cable, you will have less transmission heat loss and you keep the utility plan organised.



4. Mechanical ventilation

4.1 General

Although we tend to use as much as possible natural ventilation to keep the operation cost low, this is not possible during the entire year. In the winter we must keep the heat indoors and at those moments *Mechanical ventilation* will be needed to guarantee a good indoor climate by supplying fresh air and extract pollutants that might build up in the building (odours, CO²,...)

4.2 Ventilation calculation (+duct sizing)

In the ventilation calculation we calculate the *air amount* that needs to be displaced to maintain a healthy indoor air climate. This includes the amount of fresh air that needs to be supplied as the amount of dirty air that will be extracted.

The surface of the room that needs to be ventilated and the height of the room will have an impact on the air amount. But also the function of the room has an impact. A bathroom will need its air more refreshed than a corridor for example.

Once we know the air amount we can continue sizing the ducts. Depending on the size and the type of duct (main, branch, connection) the *air velocity* inside the duct will differ. This amount must be limited to prevent excessive noise caused by the air displacement.

Guiding air amounts

Type of building/space	Ventilation rate [l/s/m ² floor area]	Ventilation rate [l/s]
Staff rooms		
Changing room	8 – 12	
Dining room	8 – 10	15/person
Resting room		
Restaurant	10	
Cafeteria	4	
Schools		
Classroom	4 – 5	
Sport halls	3 – 4	
Bowling halls	3 – 4	
Billiard room	8 – 10	
Hospital		
Treatment and receiving rooms for infect patients	9	
Dialysis room	42	
Intensive room	28	
Injection room	28	
Post-mortem room	9	
Operating room	14	
Recovery room	28	
Timber industry		
Joiner's workshop rough	2 – 5	
Joiner's workshop fine	2 – 5	
Workshops		
Car workshop	4	60 – 80/car
Extraction of exhaust		
Mechanical workshop		
Fine mechanics	3 – 4	
Welding work	3 – 20	
Assembly shop	12 – 15	
Smithy	4 – 5	
	6 – 7	

Tabel 6: Guiding air amounts for each room

	Recommended air velocity in m/s		
	Dwellings	Schools Offices Theatre Etc.	Industrial buildings
Main duct	3,5 – 4,5	5,0 – 6,5	6,0 – 9,0
Branch duct	3,0	3,0 – 4,5	4,0 – 5,0
Connection duct	2,5	3,0 – 3,5	4,0

Tabel 7: Recommended air velocity in different types of pipes and in different types of buildings

[illegible]


Tabel 8: Ventilation calculation and duct sizing

4.3 Ventilation section

In the ventilation section we show how the different types are distributed throughout the building.

4.4 Ventilation plan


In the ventilation plan we show which rooms of a building section are supplied with fresh air and where the dirty will be extracted.




Figur 2: Section Mechanical ventilation



Figuur 4: Mechanical ventilation groundfloor



Figuur 3: Mechanical ventilation nd floor



Figuur 5: Mechanical ventilation apartment

5. Natural ventilation

5.1 General

As main ventilation source we use *natural ventilation*. To achieve this we applied a system of stack ventilation, more specifically *Atrium ventilation*.

Atrium ventilation uses a central atrium or in our case the winter garden as its heat gain (like a greenhouse), to create the upwards airflow needed for stack ventilation.


An additional benefit of this type of ventilation is that the central atrium can be used for plantation which will benefit the air quality and act as moist regulation for the building. That sort of a space can also be used as a lounge for the cafeteria and spa.

Although very beneficial, we must be aware of overheating in this during the summer time. Plants can help temper the indoor temperature, but additional measurements are needed in the form of:

- Additional (temporary) shading
- Use of thermal mass (walls, floors and soil) to better regulate the indoor temperature
- Use of heat corridors (emergency road to the winter garden, pathway through the building)

On the level of the apartments we decided to work in different levels. A lower, mid and higher level. On the lower level will have the inflow of fresh air which on its turn will gradually separate throughout the apartment and move upwards. On the highest level to exhaust of the air will take place.

5.2 Natural ventilation winter time




Figur 6: Natural ventilation air flow in the building during winter time.

In winter time there is a loss of solar gain due to shorter day time. The temperature will be much lower as well which will result in even more energy loss to the surroundings. This loss will be mainly compensated by:

- Loss of shading by vegetation
- Greenhouse effect of wintergarden
- warming process of thermal mass
- * heat pump


In winter time the system of natural, stack ventilation is driven by the captation of solar energy in the thermal mass present in the building (concrete and rammed earth walls, soil, concrete floor) during the day. The wintergarden will act as a green house and warm up the convection air which on its turn will benefit the warming process of the thermal mass. Additionally the loss of leaves of the vegetation will benefit the penetration of the solar beams into the building.

During the winter the wintergarden will be a mainly closed system to keep the warmth inside.



Figuur 7: Natural ventilation air flow in the appartment during winter time.

5.3 Natural ventilation summer time



During summer there is a much higher heat gain because of longer daytime, so more exposure to sunlight and higher outdoor temperatures. Now it will be our task to cool down the building in a way that we maintain a pleasant indoor air quality and prevent overheating. We will achieve this by:

- Opening the heat corridors (Pathways + wintergarden roof)
- Slab cooling by night of groundfloor by hollowcore slab
- Vegetation
- Thermal mass regulation
- * additional shading(sunblocking) of wintergarden

At the level of the appartements we can open the pathways for natural ventilation. But by doing so we must prevent the creating of excessive draft.



6. Be 10

The *Be10* is the final document where all the previous steps are summarized in one calculation. Where the successive calculation was still an estimate of the energy consumption, the *Be10* calculation can give a rather accurate representation.

As we mentioned before we also have to make a separation between commercial and student accommodation here.

6.1 Commercial area

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Building

Name: Punto de Reunión (commercial area)

Store: Detached house (detached single-family house)
Semi-detached and nondetached houses
Multi-storey house, Store etc or Other (non-residential)

1 Number of residential units: 15 Rotation, deg.:

1321 Heated floor area, m²: 1321 Gross area, m²:

0 Heated basement, m²: 0 Other, m²:

200 Heat capacity, Wh/K m³: Start at: End at (time):

168 Normal usage time, hours/week: 7 22

Heat supply

District: Basic: Boiler, District heating, Block heating or Electricity

☐ Heat distribution plant (if electric heating)

Contribution from (in order of priority)

☒ 1. Electric panels ☐ 2. Wood stoves, gas radiators etc.

☒ 3. Solar heat ☒ 4. Heat pump ☒ 5. Solar cells ☐ 6. Wind mills

Total heat loss

Transmission loss 14,3 kW 10,9 W/m²

Ventilation loss without HRV 37,3 kW 28,2 W/m² (in winter)

Total 51,6 kW 39,1 W/m²

Ventilation loss with HRV 1,9 kW 1,4 W/m² (in winter)

Total 16,2 kW 12,3 W/m²

Calculation rules

BR: Actual co See calculation guide

Supplement to energy frame for special conditions, kWh/m² year: 3

(Only possible for other than residential buildings and calculation rules: BR: Actual conditions)

Mechanical cooling

0,3 Share of floor area, -

Transmission loss

For building envelope excl. windows and doors: 0,8 W/m²

Tabel 9: Main building properties

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

	External walls, roofs and floors	Area (m²)	U (W/m²K)	b	Ht (W/K)	Dim. Inside (l)	Dim. Outside	Loss (W)
1	Rammed earth wall	439,149	0,03	1,00	13,1745			3095,86
2	Concrete sandwich element	218,285	0,15	1,00	32,7428	21	15	196,457
3	SL-slab storey partition (ceiling)	1321,87	0,24	1,00	317,249	21	21	0
4	Hollowcore storey partition (floor)	1321,87	0,31	0,70	286,846	21	15	2458,68
5	Rammed Earth wall wintergarden	399,094	0,03	1,00	11,9728	21	15	71,8369
6								
7								
8								
9								
10								
11								
12								
13								
14								
15								
16								
17								
18								
19								
20								

New model opened

Energy requirement 34,7 kWh/m² year, Energy frame BR 2010: 75,5 Low energy 2015: 44,8 Buildings 201: NUM

Tabel 10: Overview external walls, roofs and floors

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be 10

Punto de Reunion (hybrid)

- Building envelope
 - External walls, roofs
 - Table 1
 - Foundations etc.
 - Table 1
 - Windows and outer doors
 - Table 1
 - Shading
 - Table 1
 - Unheated rooms
 - Wintergarden
- Summer comfort
 - Ventilation
 - Table 1
- Internal heat supply
 - Lighting
 - Table 1
 - Other el. consumption
 - Basement car park
 - Mechanical cooling
 - Heat distribution plant
 - Table 1
 - Pumps
 - Pump table 1
 - Domestic hot water
 - Water heaters
 - Supply
 - Boilers
 - District heat exchan
 - Other room heating
 - Solar heating plant
 - Heat pumps
 - New heat pump
 - Solar cells

	Windows and outer doors	Numbe	Orient	Indinatio	Area (m²)	U (W/m²K)	b	Ht (W/K)	Ff (-)	g (-)	Shading	Fc (-)	Dim.Insid	Dim.Outs	Loss (W)	Ext
		28			641,44			529,149							11243,8	0/1
+1	1.6x...m Windows	1	N	90	25,809	0,82	1,00	21,1634	0,95	0,63	1.6x...m	1			592,575	0
2	1.6x...m Windows	1	E	90	30,84	0,82	1,00	25,2888	0,95	0,63	1.6x...m	1			708,086	0
3	2788x1189mm windows	6	W	90	3,02	0,82	1,00	14,8584	0,8	0,63	2788x11	1			416,035	0
4	1988x1189mm windows	2	W	90	2,13	0,82	1,00	3,4932	0,8	0,63	1988x11	1			97,8096	0
5	1988x1189mm Windows	5	N	90	2,13	0,82	1,00	8,733	0,8	0,63	1988x11	1			244,524	0
6	1988x1189mm Windows	1	E	90	2,13	0,82	1,00	1,7466	0,8	0,63	1988x11	1			48,9048	0
7	Curtain wall	1	S	90	179,965	0,82	1,00	147,571	0,95	0,5	Curtain v	0,74			4132	0
8	Curtain wall	1	E	90	68,968	0,82	1,00	56,5538	0,95	0,5	Curtain v	0,74			1583,51	0
9	Curtain wall	1	W	90	35,133	0,82	1,00	28,8091	0,95	0,5	Curtain v	0,74			806,654	0
10	Curtain wall	1	W	90	68,784	0,82	1,00	56,4029	0,95	0,63	Curtain v	0,74			1579,28	0
11	Velfac 500 (Door)	1	E	90	2,15	1	1,00	2,15	0,6	0,63	Velfac 50	1			60,2	0
12	Curtain wall to winter garden	1	S	90	161,723	0,82	1,00	132,613	0,95	0,63	Curtain v	0,74	21	15	795,677	0
13	1.6x...m Windows	1	S	90	17,458	0,82	1,00	14,3156	0,95	0,63	1.6x...m	1	21	15	85,8934	0
14	Velfac 500 (Door wintergarden)	3	S	90	2,15	1	1,00	6,45	0,6	0,63		1	21	15	38,7	0
15	Dubble door flush	2	S	90	4,5	1	1,00	9	0,6	0,63		1	21	15	54	0
16																
17																
18																
19																
20																

New model opened

NUM

Tabel 12: overview of glazed areas and outer doors

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be 10

Punto de Reunion (hybrid)

- Building envelope
 - External walls, roofs
 - Table 1
 - Foundations etc.
 - Table 1
 - Windows and outer doors
 - Table 1
 - Shading
 - Table 1
 - Unheated rooms
 - Wintergarden
- Summer comfort
 - Ventilation
 - Table 1
- Internal heat supply
 - Lighting
 - Table 1
 - Other el. consumption
 - Basement car park
 - Mechanical cooling
 - Heat distribution plant
 - Table 1
 - Pumps
 - Pump table 1
 - Domestic hot water
 - Water heaters
 - Supply
 - Boilers
 - District heat exchan
 - Other room heating
 - Solar heating plant
 - Heat pumps
 - New heat pump
 - Solar cells

	Shading	Horizon (°)	Eaves (°)	Left (°)	Right (°)	Window opening (%)
+1	1.6x...m Windows	3	16,17	0	0	4
2	2788x1189mm windows	3	4,39	0	0	4,4
3	1988x1189mm windows	3	4,39	0	0	4,4
4	Curtain wall	2	0	80,96	0	1
5	Velfac 500 (Door)	3	27,61	39,7	39,7	41,5
6	Curtain wall	0	53,95	0	0	1
7	Curtain wall	0	0	89	0	1
8	Curtain wall	0	0	0	0	1
9						
10						
11						
12						
13						
14						
15						
16						
17						
18						
19						
20						

New model opened

NUM

Tabel 11: Overview of shading by overhang, sun orientation, window opening

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (hybrid)

- Building envelope
 - External walls, roofs
 - Table 1
 - Foundations etc.
 - Table 1
 - Windows and outer
 - Table 1
 - Shading
 - Table 1
- Unheated rooms
 - Wintergarden
- Summer comfort
 - Table 1
- Ventilation
 - Table 1
- Internal heat supply
 - Table 1
- Lighting
 - Table 1
- Other el. consumption
 - Basement car park
- Mechanical cooling
 - Heat distribution plant
 - Table 1
 - Pumps
 - Pump table 1
- Domestic hot water
 - Water heaters
- Supply
 - Boilers
 - District heat exchan
 - Other room heating
 - Solar heating plant
 - Heat pumps
 - New heat pump
 - Solar cells

Unheated room

Name: Wintergarden Gross area (m²): 403

Ventilation loss

Vent (l/s m²): 25 Heat loss (W/K): 12190,8

Heat balance

Hi 132,6 W/K Hu 12313,8 W/K Temp factor 0,989

Building component	Area (m²)	U (W/m²K)	Ht (W/K)
Transmission loss from building			132,613
+1 Curtain wall to winter garden	161,723	0,82	132,613
2			
3			
4			
5			
6			
7			
8			

Building component	Area (m²)	U (W/m²K)	Ht (W/K)
Transmission loss to surroundings			123
+1 Curtain wall facing south	150	0,82	123
2			
3			
4			
5			
6			
7			
8			

New model opened

Tabel 14: Unheated rooms

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (hybrid)

- Building envelope
 - External walls, roofs
 - Table 1
 - Foundations etc.
 - Table 1
 - Windows and outer
 - Table 1
 - Shading
 - Table 1
- Unheated rooms
 - Wintergarden
- Summer comfort
 - Table 1
- Ventilation
 - Table 1
- Internal heat supply
 - Table 1
- Lighting
 - Table 1
- Other el. consumption
 - Basement car park
- Mechanical cooling
 - Heat distribution plant
 - Table 1
 - Pumps
 - Pump table 1
- Domestic hot water
 - Water heaters
- Supply
 - Boilers
 - District heat exchan
 - Other room heating
 - Solar heating plant
 - Heat pumps
 - New heat pump
 - Solar cells

Ventilation	Area (m²)	Fo, -	qm (l/s m²)	n vgr (-)	ti (°C)	EL-HC	qn (l/s m²)	qn (l/s m²)	SEL (kl/m³)	qm,s (l/s m²)	qn,s (l/s m²)	qm,n (l/s m²)	qn,n (l/s m²)
Zone	907,151	Winter				0/1	Winter	Winter		Summer	Summer	Night	Night
+1 Café	142,5	0,75	1,1	0,95	18	0	0	0,3	0,5	1,1	3	0	2,5
2 Kitchen	36	0,75	2,7	0,95	18	0	0	0,3	0,5	2,7	2	0	2
3 Polyvalent room	250	0,75	1,1	0,95	18	0	0	0,3	0,5	1,1	3	0	2,5
4 storage room	20,9	0,75	0,27	0,95	18	0	0	0,3	0,5	0,27	0	0	0
5 Office	40,92	0,75	0,55	0,95	18	0	0	0,3	0,8	0,55	2	0	2
6 Doctors room	19,95	0,75	0,83	0,95	18	0	0	0,3	0,8	0,83	2	0	2
7 Massage room 1	16,005	0,75	1,1	0,95	18	0	0	0,3	0,8	1,1	2	0	1,5
8 Massage room 2	12,045	0,75	1,1	0,95	18	0	0	0,3	0,8	1,1	2	0	1,5
9 Massage room 3	10,89	0,75	1,1	0,95	18	0	0	0,3	0,8	1,1	2	0	1,5
10 Massage room 4	10,89	0,75	1,1	0,95	18	0	0	0,3	0,8	1,1	2	0	1,5
11 Massage room 5	13,984	0,75	1,1	0,95	18	0	0	0,3	0,8	1,1	2	0	1,5
12 Reception	85,84	0,75	0,5	0,95	18	0	0	0,3	0,5	0,5	3	0	2,5
13 Toilets 1	23,76	1	1,9	0,95	18	0	0	0,3	0,8	1,9	1	0	1
14 Toilets 2	11,9	1	1,9	0,95	18	0	0	0,3	0,8	1,9	2	0	1
15 Toilets 3	22,96	1	1,9	0,95	18	0	0	0,3	0,8	1,9	2	0	1,5
16 Showers	51,8	0,75	2,22	0,95	18	0	0	0,3	0,5	2,22	2	0	2
17 Spa	270	1	1,1	0,95	18	0	0	0,3	0,5	1,1	3,5	0	2,5
18 Sauna 1	11,9	0,75	1,38	0,95	18	0	0	0,3	0,8	1,38	1	0	1
19 Sauna 2	12,95	0,75	1,38	0,95	18	0	0	0,3	0,8	1,38	1	0	1
20 Changing rooms	34,8	0,75	2,5	0,95	18	0	0	0,3	0,5	2,5	2	0	1,5

New model opened

Tabel 13: Ventilation calculation

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

SBI Direction 213: Energy demand of buildings, Be10

Internal heat supply	Area (m²)	Persons (W/m²)	App. (W/m²)	App.night (W/m²)
Zone	1100,0	11815,2 W	4389,8 W	0,0 W
+1 Café	142,5	10	5	0
2 Kitchen	36	3	5	0
3 Polyvalent room	250	20	5	0
4 storage room	20,9	0	0	0
5 Office	40,92	4	5	0
6 Doctors room	19,95	2	2	0
7 Massage room 1	16,005	2	2	0
8 Massage room 2	12,045	2	2	0
9 Massage room 3	10,89	2	2	0
10 Massage room 4	10,89	2	2	0
11 Massage room 5	13,984	2	2	0
12 Reception	85,84	6	2	0
13 Toilets 1	23,76	1	1	0
14 Toilets 2	11,9	1	1	0
15 Toilets 3	22,96	1	1	0
16 Showers	51,8	2	0	0
17 Spa	270	15	6	0
18 Sauna 1	11,9	2	1	0
19 Sauna 2	12,95	2	1	0
20 Changing rooms	34,8	5	0	0

New model opened

NUM 10:12 23/06/2015

Tabel 15: Internal heat gain

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10


SBI Direction 213: Energy demand of buildings, Be10

Lighting	Area (m²)	General (V)	General (V)	Lighting (L)	DF (%)	Control (U, M)	Fo (-)	Work (W/m²)	Other (W/m²)	Stand-by (V)	Night (W/m²)
Lighting zone	1105,8	Min.	Inst.								
+1 Café	143	3	2	120	36	K	1	1	0	0	0
2 Offices	61	3	2	200	18	K	1	1	0	0	0
3 Spa	270	3	2	100	28	K	1	1	0	0	0
4 Changing Rooms	35	3	2	100	9	K	0,8	1	0	0	0
5 Reception	86	3	2	200	36	K	0,8	1	0	0	0
6 Massage rooms	64	3	2	120	18	K	0,6	1	0	0	0
7 Polyvalent room	254	3	1	120	36	K	0,6	1	0	0	0
8 Storage room	23	3	0	50	0	M	0,2	0	0	0	0
9 Kitchen	36	3	2	200	18	M	1	1	0	0	0
10 Toilets	57	3	0	120	0	M	0,6	1	0	0	0
11 Sauna's	25	3	1	100	0	M	0,8	0	0	0	0
12 Showers	51,8	3	2	120	28	M	0,8	1	0	0	0
13	0	0	0	0	0	U	0	0	0	0	0
14											
15											
16											
17											
18											
19											
20											


New model opened

NUM 10:12 23/06/2015

Tabel 16: overview lighting per room



Tabel 18: Additional supply solar cells (incorporated in roof winter garden)



Tabel 17: Overview energy requirements and key numbers

Be10 calculation Punto De Reunion mechanical ventilation commercial area - Be10

File Edit View Help

SB Direction 213: Energy demand of buildings, Be 10

Punto de Reunion (commercial)

External walls, roofs etc.

Table 1

Foundations etc.

Table 1

Windows and outer door

Table 1

Shading

Table 1

Unheated rooms

Wintergarden

Summer comfort

Ventilation

Table 1

Internal heat supply

Table 1

Lighting

Table 1

Other e.c. consumption

Basement car parkings

Mechanical cooling

Heat distribution plant

Pumps

Pump table 1

Domestic hot water

Water heaters

Supply

Boilers

District heat exchanger

Other room heating

Solar heating plant

Heat pumps

New heat pump

Solar cells

New solar cells

Wind mills

Results

Key numbers

Measures

MMh:	January	February	March	April	May	June	July	August	September	October	November	December	Total
Heating requirement													
1) Trans- and vent. loss	15.44	14.37	13.38	9.42	4.40	0.91	-0.37	-0.19	3.17	6.46	10.14	13.57	90.69
2) Vent. VF (total)	2.80	2.55	2.69	2.42	2.21	1.97	1.96	1.97	2.09	2.32	2.45	2.70	26.13
3) Vent. VSV down reg.	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
4) Heat loss	12.64	11.82	10.69	7.00	2.19	0.00	0.00	0.00	1.08	4.13	7.69	10.87	62.55
5) Incident solar radiation	6.78	10.07	14.76	19.38	22.82	21.52	21.51	21.33	16.92	11.87	7.30	4.63	176.90
6) Internal supply	15.31	13.83	15.31	14.82	15.31	14.82	15.31	15.31	14.82	15.31	14.82	15.31	180.28
7) From pipe and VVB const.	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
8) Total supplement	22.09	23.90	30.08	34.20	38.13	36.34	36.82	36.65	31.73	27.18	22.12	19.94	359.18
9) Rel. supplement, -	1.75	2.02	2.81	4.88	17.46	2.53	2.53	2.53	29.28	6.58	2.88	1.83	
10) Part of room heating	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
11) Variable heat supplement	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
12) Total supplement	22.09	23.90	30.08	34.20	38.13	36.34	36.82	36.65	31.73	27.18	22.12	19.94	359.18
13) Rel. supplement, -	1.75	2.02	2.81	4.88	17.46	2.00	2.00	2.00	29.28	6.58	2.88	1.83	
14) Utilization factor	0.54	0.48	0.35	0.20	0.06	0.48	0.48	0.48	0.03	0.15	0.34	0.52	
15) Heat requirement	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00	0.00
16) Vent. VF (central heating)	2.80	2.55	2.69	2.42	2.21	1.97	1.96	1.97	2.09	2.32	2.45	2.70	26.13
17) Total	2.80	2.55	2.69	2.42	2.21	1.97	1.96	1.97	2.09	2.32	2.45	2.70	26.13

Tabel 19: Overview heating requirements

6.2 Student accomodation

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (mechanical ventilation housing)

Building envelope

- External walls, roofs and foundations etc.
- Windows and outer doors
- Shading
- Unheated rooms
- Summer comfort
- Ventilation
- Internal heat supply
- Lighting
- Other el. consumption
- Basement car parkings
- Mechanical cooling
- Heat distribution plant
- Pumps
- Domestic hot water
- Water heaters
- Supply
- Boilers
- District heat exchanger
- Other room heating
- Solar heating plant
- Heat pumps
- New heat pump
- Solar cells
- Wind mills
- Results
- Key numbers
- Heating requirement

Building Name: **Punto de Reunion (mechanical ventilation housing)**

Multi-sto

1 Number of residential units: 15 Rotation, deg.

1182 Heated floor area, m²: 1182 Gross area, m²

0 Heated basement, m²: 0 Other, m²

160 Heat capacity, Wh/K m³: Start at End at (time)

168 Normal usage time, hours/week: 15 2

Calculation rules

BR: Actual co See calculation guide

Supplement to energy frame for special conditions, kWh/m² year: 1

(Only possible for other than residential buildings and calculation rules: BR: Actual conditions)

Mechanical cooling

0,5 Share of floor area, -

Description

Comments

Heat supply

District h Basis: Boiler, District heating, Block heating or Electricity

Heat distribution plant (if electric heating)

Contribution from (in order of priority)

☒ 1. Electric panels ☒ 2. Wood stoves, gas radiators etc.

☒ 3. Solar heat ☒ 4. Heat pump ☒ 5. Solar cells ☐ 6. Wind mills

Total heat loss

Transmission loss 9,9 kW 8,4 W/m²

Ventilation loss without HRV 56,9 kW 48,2 W/m² (in winter)

Total 66,8 kW 56,5 W/m²

Ventilation loss with HRV 16,4 kW 13,9 W/m² (in winter)

Total 26,3 kW 22,3 W/m²

Transmission loss

For building envelope excl. windows and doors

0,8 W/m²

Tabel 21: overview building properties

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Windows and outer doors	Number	Orient	Inclination	Area (m²)	U (W/m²K)	b	g (W/m²K)	g (°)	g (°)	Shading	Fc (°)	Dim. Inside (°)	Dim. Outside (°)	Loss (W)	Ext
1 Large window	1	W	90	81,8	0,82	1,00	6,888	0,95	0,5	1189x1189mm	-0,7			2146,43	0
2 16x11 Windows	3	N	90	2,8	0,82	1,00	6,888	0,8	0,63	1189x1189mm	-0,7			220,458	0
3 2600x1189mm windows	3	W	90	2,8	0,82	1,00	6,888	0,8	0,63	2600x1189mm	-0,7			220,458	0
4 2600x1189mm windows	2	W	90	2,13	0,82	1,00	3,4932	0,8	0,63	2600x1189mm	-0,7			111,782	0
5 1889x1189mm windows	8	N	90	2,13	0,82	1,00	11,9728	0,8	0,63	1889x1189mm	-0,7			440,13	0
6 1889x1189mm windows	7	E	90	2,13	0,82	1,00	12,2262	0,8	0,63	1889x1189mm	-0,7			391,238	0
7 1889x1189mm windows	4	S	90	2,13	0,82	1,00	6,8884	0,8	0,63	1189x1189mm	-0,7			223,565	1
8 Large windows	1	N	90	13,5	0,82	1,00	11,07	0,95	0,5	Large window	-0,8			354,24	0
9 Large windows	1	S	90	14,1	0,82	1,00	44,362	0,95	0,5	Large window	-0,8			1419,38	1
10 Double doors	2	W	90	5,2	0,9	1,00	9,36	0,6	0,63	Double door	0,74			296,52	0
11 Skylight	1	W	10	46	0,82	1,00	33,72	0,6	0,63	verflec 300 (Dac)	-0,8			1207,04	0
12 Skylight	1	E	10	22,5	0,82	1,00	18,45	0,6	0,63	1189x1189mm	-0,8			890,4	0
13 1189x1189mm window (wintergarden)	3	E	90	1,21	0,82	0,70	2,08362	0,7	0,63	1189x1189mm	0,7	21	15	17,8996	1
14 Double door (wintergarden)	2	E	90	5,2	0,9	0,70	6,352	0,6	0,63		0,74	21	15	96,38	1
15 Verflec glass door (wintergarden)	2	W	90	2,1	0,9	0,70	2,646	0,6	0,63		0,74	21	15	22,68	1
16 Verflec glass door (wintergarden)	1	S	90	2,1	0,9	0,70	1,323	0,6	0,63		0,74	21	15	11,34	1
17 Large window (wintergarden)	1	W	90	29,1	0,82	0,70	16,7024	0,95	0,5		-0,8	21	15	143,172	1
18 Large window (wintergarden)	1	S	90	7,8	0,82	0,70	4,305	0,95	0,5		-0,8	21	15	36,9	1
19 1189x1189mm window (wintergarden)	1	S	90	1,21	0,82	0,70	0,69494	0,7	0,63		0,7	21	15	5,9532	1
20 1189x1189mm window (wintergarden)	1	W	90	1,21	0,82	0,70	0,69494	0,7	0,63		0,7	21	15	5,9532	1

Tabel 20: Overview properties of exterior walls, roofs and floors

File Edit View Help

Be10 calculation Punto De Reunion mechanical accommodation - Be10

SB Direction 213: Energy demand of buildings, Be10

Punto de Reunion (mechanical)

	Shading	Horizon (°)	Eaves (°)	Left (°)	Right (°)	Window opening (%)
Building envelope						
External walls, roofs and foundations etc.						
Table 1						
Windows and outer doors						
Table 1						
Shading						
Unshaded rooms						
Summer comfort						
Ventilation						
Table 1						
Internal heat supply						
Table 1						
Lighting						
Table 1						
Other el. consumption						
Basement car parkings						
Mechanical cooling						
Heat distribution plant						
Table 1						
Pumps						
Pump table 1						
Domestic hot water						
Water heaters						
Supply						
Boilers						
District heat exchanger						
Other room heating						
Solar heating plant						
Heat pumps						
Low heat pump						
Solar cells						
Wind mills						
Results						
Key numbers						
Heating requirement						

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20

Tabel 23: Overview properties of glazed areas and doors.

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10								
File Edit View Help								
SB Direction 213: Energy demand of buildings, Be10								
Punto de Reunion (mechanical)								
Building envelope	External walls, roofs and floors	Area (m²)	U (W/m²K)	b	Ht (W/K)	Dim Inside (C)	Dim Outside (C)	Loss (W)
External walls, roofs and floors		2555,67		Click	307,354			1845
Foundations etc.	wooden walls	575,8	0,09	1,00	51,822			1658,3
Table 1	Concrete sandwich element	230	0,15	0,70	24,15	21	15	207
Windows and outer doors	RI-slab storey partition (floor)	830	0,34	1,00	199,2	21	21	0
Table 1	Wooden roof	572,1	0,04	1,00	22,684	0	0	0
Shading	Wooden walls winter garden	275,57	0,03	0,70	5,78697	21	15	49,6026
Table 1	Wooden roof winter garden	19	0,04	0,70	0,532	21	15	4,56
Unheated rooms	Wooden floor winter garden (overhang)	53,2	0,08	0,70	2,9792	21	15	25,536
Summer comfort								
Ventilation								
Table 1								
Internal heat supply								
Table 1								
Lighting								
Table 1								
Other el. consumption								
Basement car parkings								
Mechanical cooling								
Heat distribution plant								
Table 1								
Pumps								
Pump table 1								
Domestic hot water								
Water heaters								
Supply								
Solar								
District heat exchanger								
Other room heating								
Solar heating plant								
Heat pumps								
New heat pump								
Solar cells								
Wind mills								
Results								
Key numbers								
Heating requirement								

Tabel 22: overview of shading

Tabel 24: Summer comfort calculation

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (mechanic)

- Building envelope
 - External walls, roofs and floors
 - Foundations etc.
 - Windows and outer doors
 - Shading
- Unheated rooms
- Summer comfort
- Ventilation
- Internal heat supply
- Lighting
- Other el. consumption
- Basement car parkings
- Mechanical cooling
- Heat distribution plant
- Pumps
- Pump table 1
- Domestic hot water
- Water heaters
- Supply
 - Boilers
 - District heat exchanger
 - Other room heating
 - Solar heating plant
 - Heat pumps
- Solar cells
- Wind mills
- Results
- Key numbers
- Heating requirement

Most heated room (only dwellings)

Floor area, m² 492 Calculate

Ventilation, l/s m²

Winter 0,3

Summer, day 0,9 night 0,6

Number of hours above

26 °C 27 °C

13 0

Tabel 26: summer comfort calculation

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

File Edit View Help

SBI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (mechanic)

- Building envelope
 - External walls, roofs and floors
 - Foundations etc.
 - Windows and outer doors
 - Shading
- Unheated rooms
- Summer comfort
- Ventilation
- Internal heat supply
- Lighting
- Other el. consumption
- Basement car parkings
- Mechanical cooling
- Heat distribution plant
- Pumps
- Pump table 1
- Domestic hot water
- Water heaters
- Supply
 - Boilers
 - District heat exchanger
 - Other room heating
 - Solar heating plant
 - Heat pumps
- Solar cells
- Wind mills
- Results
- Key numbers
- Heating requirement

Ventilation	Area (m ²)	Fo. -	q _{in} (l/s m ²)	n _{exp} (-)	θ (°C)	E-HC	q _{in} (l/s m ²)	q _{in} (l/s m ²)	SEL (l/s m ²)	q _{in} (l/s m ²)	q _{in} (l/s m ²)	q _{in} (l/s m ²)	q _{in} (l/s m ²)
Zone			Winter				Winter	Winter		Summer	Summer	Night	Night
1 Kitchen (x7)	96	1	2,7	0,95	18	0	0,3	0,07	1	2,7	1,5	0	1,5
2 Livingroom (x7)	224	1	0,13	0,95	18	0	0,3	0,07	1	0,13	1,5	0	1,5
3 Diningroom (x7)	212	1	0,13	0,95	18	0	0,3	0,07	1	0,13	1,5	0	1,5
4 Study (x7)	105	1	0,13	0,95	18	0	0,3	0,07	1	0,13	1,5	0	1,5
5 Bathroom (x7)	77	1	2,7	0,95	18	0	0,3	0,07	1	2,7	1,5	0	1,5
6 Bedroom (x12)	207	1	0,13	0,95	18	0	0,3	0,07	1	0,13	1,5	0	1,5
7 Livingdiningkitchen (loft)	152	1	2,7	0,95	18	0	0,3	0,07	1	2,7	1,5	0	1,5
8 Study (loft)	72	1	0,13	0,95	18	0	0,3	0,07	1	0,13	1,5	0	1,5
9 Bedroom (x3 loft)	46	1	0,13	0,95	18	0	0,3	0,07	1	0,13	1,5	0	1,5
10 Bathroom (x3 loft)	39	1	2,7	0,95	18	0	0,3	0,07	1	2,7	1,5	0	1,5
11	0	0	0	0	0	0	0	0	0	0	0	0	0
12	0	0	0	0	0	0	0	0	0	0	0	0	0
13	0	0	0	0	0	0	0	0	0	0	0	0	0
14	0	0	0	0	0	0	0	0	0	0	0	0	0
15	0	0	0	0	0	0	0	0	0	0	0	0	0
16	0	0	0	0	0	0	0	0	0	0	0	0	0
17	0	0	0	0	0	0	0	0	0	0	0	0	0
18	0	0	0	0	0	0	0	0	0	0	0	0	0
19	0	0	0	0	0	0	0	0	0	0	0	0	0
20	0	0	0	0	0	0	0	0	0	0	0	0	0

Tabel 25: ventilation calculation

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

Internal heat supply				
Zone	Area (m²)	Persons (W/m²)	App. (W/m²)	App. night (W/m²)
1 Kitchen (x7)	68	7	14	0
2 Livingroom (x7)	224	7	7	0
3 Diningroom (x7)	212	7	7	0
4 Study (x7)	105	7	7	0
5 Bathroom (x7)	77	7	7	0
6 Bedroom (x12)	207	18	12	0
7 Kitchen/livingdining (loft)	152	6	8	0
8 Bedroom (x3 loft)	72	4	2	0
9 Study (loft)	46	1	1	0
10 Bathroom (x3 loft)	39	2	4	0
11	0	0	0	0
12	0	0	0	0
13	0	0	0	0
14	0	0	0	0
15	0	0	0	0
16	0	0	0	0
17	0	0	0	0
18	0	0	0	0
19	0	0	0	0
20	0	0	0	0

Tabel 28:overview internal heat supply

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

Lighting											
Lighting zone	Area (m²)	General (W/m²)		Lighting (lux)	DF (%)	Control (U, M, A, K)	Fa (-)	Work (W/m²)	Other (W/m²)	Stand-by (W/m²)	Night (W/m²)
		Min.	Inst.								
1 Kitchen (x7)	68	2	1	150	18	M	0.6	1	0	0	0
2 Livingroom (x7)	224	2	0	120	18	M	0.6	1	0	0	0
3 Diningroom (x7)	212	2	0	120	18	M	0.6	1	0	0	0
4 Study (x7)	105	1	0	120	18	M	0.4	1	0	0	0
5 Bathroom (x7)	77	2	1	150	6	M	0.4	1	0	0	0
6 Bedroom (x12)	207	1	0	100	18	M	0.3	1	0	0	0
7 Kitchen/livingdining (loft)	152	2	1	150	36	M	0.8	1	0	0	0
8 Bedroom (x3 loft)	72	1	0	100	23	M	0.4	1	0	0	0
9 Study (loft)	46	1	0	120	23	M	0.4	1	0	0	0
10 Bathroom (x3 loft)	39	2	1	150	18	M	0.4	1	0	0	0
11	0	0	0	0	0	M	0	0	0	0	0
12	0	0	0	0	0	M	0	0	0	0	0
13	0	0	0	0	0	U	0	0	0	0	0
14											
15											
16											
17											
18											
19											
20											

Tabel 27: Overview lighting

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

File Edit View Help

SRI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (mechanic)

- Building envelope
 - External walls, roofs and foundations etc.
 - Table 1
 - Windows and outer doors
 - Table 1
 - Shading
 - Table 1
 - Unheated rooms
- Summer comfort
- Ventilation
 - Table 1
- Internal heat supply
 - Table 1
- Lighting
 - Table 1
- Other el. consumption
 - Basement car parkings
- Mechanical cooling
 - Heat distribution plant
 - Table 1
 - Pumps
 - Pump table 1
 - Water heaters
- Supply
 - Boilers
 - District heat exchanger
 - Other room heating
 - Solar heating plant
- Heat pumps
 - Solar cells
 - Wind mills

- Results
- Key numbers
- Heating requirement

Key numbers, kWh/m² year

Energy frame in BR 2010

Without supplement	Supplement for special conditions	Total energy frame
53,9	0,0	53,9
Total energy requirement		27,2

Energy frame low energy buildings 2015

Without supplement	Supplement for special conditions	Total energy frame
30,8	0,0	30,8
Total energy requirement		26,0

Energy frame Buildings 2020

Without supplement	Supplement for special conditions	Total energy frame
20,0	0,0	20,0
Total energy requirement		18,9

Contribution to energy requirement

Heat	5,6
El. for operation of building	8,6
Excessive in rooms	0,0

Net requirement

Room heating	5,6
Domestic hot water	0,0
Cooling	0,0

Selected electricity requirements

Lighting	24,2
Heating of rooms	0,0
Heating of DHW	0,0
Heat pump	0,4
Ventilators	8,2
Pumps	0,0
Cooling	0,0
Total el. consumption	80,8

Heat loss from installations

Room heating	0,0
Domestic hot water	0,0

Output from special sources

Solar heat	0,0
Heat pump	0,0
Solar cells	0,0
Wind mills	0,0

Tabel 29: Overview energy requirements/ key numbers

Be10 calculation Punto De Reunion mechanical ventilation accommodation - Be10

File Edit View Help

SRI Direction 213: Energy demand of buildings, Be10

Punto de Reunion (mechanic)

- Building envelope
 - External walls, roofs and foundations etc.
 - Table 1
 - Windows and outer doors
 - Table 1
 - Shading
 - Table 1
 - Unheated rooms
- Summer comfort
- Ventilation
 - Table 1
- Internal heat supply
 - Table 1
- Lighting
 - Table 1
- Other el. consumption
 - Basement car parkings
- Mechanical cooling
 - Heat distribution plant
 - Table 1
 - Pumps
 - Pump table 1
 - Water heaters
- Supply
 - Boilers
 - District heat exchanger
 - Other room heating
 - Solar heating plant
- Heat pumps
 - Solar cells
 - Wind mills

- Results
- Key numbers
- Heating requirement

MWh

	January	February	March	April	May	June	July	August	September	October	November	December	Total
Heating requirement													
1) Trans- and vent. loss	15,07	13,98	13,28	9,77	5,46	2,36	1,30	1,47	4,33	7,25	10,40	13,44	98,11
2) Vent. VF (total)	0,92	0,85	0,81	0,59	0,33	0,14	0,08	0,09	0,26	0,44	0,63	0,82	5,97
3) Vent. VGF down reg.	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00
4) Heat loss	14,15	13,13	12,47	9,18	5,12	2,22	1,22	1,38	4,07	6,81	9,77	12,62	92,14
5) Incident solar radiation	0,42	0,76	1,36	1,35	2,77	2,80	2,72	2,32	1,03	0,94	0,47	0,27	17,22
6) Internal supply	14,74	13,31	14,74	14,26	14,74	14,26	14,74	14,74	14,26	14,74	14,26	14,74	173,50
7) From pipe and VFB const.	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00
8) Total supplement	15,15	14,06	16,10	15,61	17,51	17,06	17,46	17,06	15,29	15,68	14,73	15,01	190,72
9) Rel. supplement -	1,07	1,07	1,29	1,70	3,42	7,68	14,27	12,39	3,76	2,30	1,51	1,19	
10) Part of room heating	0,58	0,54	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	
11) Variable heat supplement	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	
12) Total supplement	15,15	14,06	16,10	15,61	17,51	17,06	17,46	17,06	15,29	15,68	14,73	15,01	190,72
13) Rel. supplement -	1,07	1,07	1,29	1,70	3,42	7,68	14,27	12,39	3,76	2,30	1,51	1,19	
14) Utilization factor	0,89	0,89	0,77	0,59	0,29	0,13	0,07	0,08	0,27	0,43	0,66	0,82	
15) Heat requirement	0,38	0,33	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,00	0,71
16) Vent. VF (central heating)	0,92	0,85	0,81	0,59	0,33	0,14	0,08	0,09	0,26	0,44	0,63	0,82	5,97
17) Total	1,30	1,18	0,81	0,59	0,33	0,14	0,08	0,09	0,26	0,44	0,63	0,82	6,68

Tabel 30: Overview heating requirements.